



SAFE STORAGE OF OXYGEN CYLINDERS



Please follow these guidelines in order to safely store your Oxygen Cylinders according to OSHA 1926.350:

- ✈️ Notify the Airport General Manager or FBO Line Services Manager if you are storing Oxygen Cylinders in your hangar.
- ✈️ A suitable cylinder truck, chain, or other steadying device shall be used to keep cylinders from being knocked over while stored or in use.
- ✈️ Inside hangars, cylinders shall be stored in a well-protected, well-ventilated, dry location, at least 20 feet (6.1 m) from highly combustible materials such as oil or gas.
- ✈️ If multiple cylinders are stored, they should be in a consolidated location.
- ✈️ Storage spaces shall be located where cylinders will not be knocked over or damaged by passing or falling objects, or subject to tampering by unauthorized persons.
- ✈️ Cylinders shall not be kept in unventilated enclosures such as lockers and cupboards.
- ✈️ Valve protection caps shall be in place and secured.